



Meeting Date: 09/18/12

| ACTION | TYPE OF ITEM |
|--|--|
| <input type="checkbox"/> Approved Recommendation | <input checked="" type="checkbox"/> Info/Consent |
| <input type="checkbox"/> Ord. No(s). _____ | <input type="checkbox"/> Report |
| <input type="checkbox"/> Res. No(s). _____ | <input type="checkbox"/> Public Hearing (Info/consent) |
| <input type="checkbox"/> Other _____ | <input type="checkbox"/> Other _____ |

Prepared By: Lou Balderrama, City Engineer Agenda Item No. I-4

Reviewed By: City Manager [Signature] City Attorney [Signature] Finance [Signature] Public Works

DATE: September 5, 2012

TO: City Council

FROM: Rob Roshanian, Interim Public Works Director [Signature]
Public Works

SUBJECT: PW 12-16 Wells Numbers 22, 32 and 33 Rehabilitation Project

RECOMMENDATION

That City Council approve Project Specification No. PW 12-16 for the rehabilitation of Wells Numbers 22, 32 and 33, located at 251 South Hayes Avenue, and authorize staff to solicit bids for the project.

DISCUSSION

Wells Numbers 22, 32 and 33 are in immediate need of repair or rehabilitation. Wells Numbers 32 and 33 provide groundwater to the City's Desalter Number 1 (Desalter). Having these two wells off-line has left Well Number 34 as the sole groundwater supply for the Desalter. Well Number 22 provides water to blend with the Desalter permeate water. The loss of production from these three wells has severely limited the City's ability to produce its own groundwater.

The successful bidder will remove pumping equipment from each well; inspect the pumping equipment and the wells; perform rehabilitation to the wells, gravel packs and formations; repair and/or replace pumping equipment; reinspect the wells; install the pumping equipment; and test the wells and pumping equipment.

After the project bids are received and evaluated, staff will return to City Council to recommend approval of the lowest responsible bidder.

FINANCIAL IMPACT

The estimated cost of this work is \$900,000. There are sufficient funds in the Water Procurement Division of the Water Operating Fund (Account No. 601-6010-843-8606) to cover the cost of this work.

Attachment #1 - Project Site Map

Note: Plans and specifications for PW 12-16 Wells 22, 32 and 33 Rehabilitation Project are available for review at the City of Oxnard Corporation Yard, General Services Department, Building No. 2, 1060 Pacific Avenue, from 8:00 a.m. on Thursday prior to the City Council Meeting.

